

April 29, 2021

Attention: Ritesh Shah
VERITAS STAINLESS CO PVT LTD
UNIT NO A-47-A ROYAL INDI HUB
BHIWANDI KAMAN ROAD VASAI DIST PALGHAR
MAHARASHTRA, 401208

The design submission, tracking number 2021-01795, originally received on April 06, 2021 was surveyed and accepted for registration as follows:

CRN : 0B21437.2 **Accepted on:** April 29, 2021
Reg Type: NEW DESIGN **Expiry Date:** April 29, 2031
Drawing No. : FORGED FLANGES-SCOPE ATTACHED TO AB-41 FORM As Noted
Fitting type: FORGED FLANGES 1/2" TO 48"

The registration is conditional on your compliance with the following notes:

- This registration is based on the understanding that the flanges are in full compliance with ASME B16.5 and B16.47 including size, thickness and material.


As indicated on AB-41 Statutory Declaration form and submitted documentation, the code of construction are B16.5 and B16.47.

- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration form.
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date.
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (780) 433-0281 ext 3369 or fax (780) 437-7787 or e-mail Radisavljevic@absa.ca.

Sincerely,



RADISAVLJEVIC, ZANA, P. Tech. (Eng.)
DOP Cert. No. D00003136

STATUTORY DECLARATION Registration of Fittings

Single or Multiple Fitting Designs within one Fitting Category

I Ritesh Shah Director
(name of applicant) (position title) (must be in a position of authority)
of Veritas Stainless Co. Pvt. Ltd
(name of manufacturer)

located at Unit No.A-47-A, Royal Indl. Hub, Bhiwandi Kaman Road, Vasai -401208
Dist. Palghar, Maharastra, INIDA (plant address)

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act
(select only one)



- ☒ comply with the requirements of ANSI B16.5, B16.47 Series A & B which specifies the dimensions,
(title of recognized North American Standard)
materials of construction, pressure/temperature ratings and identification marking of the fittings, or
- ☐ are not covered by the provisions of a recognized North American standard and are therefore
manufactured to comply with _____ as supported by the
(title of code of construction or other applicable document)
attached data which identifies the dimensions, materials of construction, pressure/temperature ratings
and the basis for such ratings, and the identification marking of the fittings.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified as described in the below Table as being suitable for the manufacturing of these fittings to the stated standard, regulation, code, guideline or other applicable document. The fittings covered by the declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

Quality Program Verification and Manufacturing Sites

A copy of the Quality Certificate from each manufacturing site must be included

Item #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	Manufacturer of Flanges, Fitting & Stub Ends	ISO 9001 : 2015 Quality Assurance		2023-12-22	TUV Rheinland	Unit No.A-47-A, Royal Industrial Hub, Bhiwandi Kaman Road, Vasai -401208 Dist. Palghar, Maharastra, INDIA
2.	Manufacturer of Flanges, Fitting & Stub Ends	PED 2014/68/EU Quality Management		2023-11-11	TUV Rheinland	Same as above

Tracking #: 2021-01795



In support of this application, the following information, calculations and/or test data are attached:



(Signature of the Declarer)

(Date)

DECLARED before me at Vasai, _____ in the _____ City _____ of Maharashtra, India
(city) (province, territory, or state)
this 5th day of April, 2021
(Month) (Year)

(print) _____
(a Commissioner of Oaths or Notary Public)

(sign) _____
(a Commissioner of Oaths or Notary Public)

(expiry date (mm/dd/yy))

Commissioner of Oaths / Notary Public in and for: _____
(province, territory, or state)

For ABSA Office Use Only:

NOTES: _____

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Part 1, Clause 4.2, and is accepted for registration in Category B.

CRN: _____

Registered Date: _____

Expiry Date: April 4, 2031

Signature: _____
(Signature of the Administrator/SCO)

The information you provide is necessary only for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline

2021-01795

ABSA

SAFETY CODES ACT - PROVINCE OF ALBERTA

ACCEPTED: 0B21437.2

See acceptance letter for conditions of registration.

Date: 2021-04-29 By: Zana Radisavljevic

ZANA RADISAVLJEVIC, P. Tech. (Eng.)

This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.

Table 1 Scope of Fitting Designs**

Item #	Primary Pressure Bearing / Retaining Component	Material of Construction	Port Connections and Size Range	MDMT	Rated Pressure		Pressure Class(es) / Schedule(s)	Design Code(s) of Construction	Reference Catalogue (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature			
1	Forge Flanges	CS, SS & AS	1/2" to 48"				150# to 2500#	ANSI B16.5 & B16.47	Catalogue

Table 2 Additional Scope Information

List/Attach Additional Detail and References (Product Configurations, Options, Illustrations, etc.)
Example:
Series X Options

** For additional alternatives of Table 1, refer to Form AB-41a, Guide for Completing Form AB-41

